



OFFICE OF WILL COUNTY EXECUTIVE
LAWRENCE M. WALSH

Will County Office Building – 302 N Chicago Street – Joliet, Illinois 60432

Kevin Lynn
Purchasing Director

(815) 740-4712
Fax (815) 740-4604
klynn@willcountyillinois.com

BID #2020-49 WC Data Center CRAC unit

February 14, 2020
ADDENDUM 1

Please note, there was an error listed in the original bid listing the due date on Thursday. This bid is due Wednesday, February 19, 2020

We received the following questions regarding the bid listed above:

Question #1: Will there be any drawings released for properly bidding the IT CRAC unit replacement project, or are we solely following the scope and what we saw at the walkthrough?

Answer #1: No drawings to be provided. Yes, solely on scope and walk thru.

Question # 2: Will there be any new piping in the system or will it just be connecting the new Liebert system and the dry coolers to the existing piping?

Answer #2: No new piping is expected.

Question #3: How heavy is the existing dry cooler on the roof that will need to be demo'd and removed?

Answer #3: We don't have that information but since a new one is to replace it, it should be comparable.

Question #4: I understand that we are furnishing and installing the new Liebert glycol system per the scope of work, is the mechanical contractor also furnishing the dry coolers or just installing? (referencing Scope of work C.1C)

Answer #4: Yes furnish the dry coolers and install.